



Republic of the Philippines  
**Department of Education**  
REGION III  
SCHOOLS DIVISION OF BULACAN

---

March 8, 2022

To: Concerned Public Elementary School Principals  
(Through the District Supervisors)

Attached please find the letter of Mr. Arnaldo C. Punay, Manager, Meralco Malolos Business Center dated March 8, 2022 recommending School/Barangay/Entity management to undertake electrical repairs/replacements in selected schools by a duly licensed electrician before the scheduled date of the 2022 National and Local Elections.

Queries and other clarifications may be coursed directly to the Meralco Malolos Business Center Relationship Manager, Mr. Eduardo D. Mendoza at cellphone no. 09989689706.

Very truly yours,

  
**ZENIA G. MOSTOLES, EdD, CESO V**  
Schools Division Superintendent

Division Letter No. 015 S. 2022





RECEIVED  
MAR 08 2022  
By: \_\_\_\_\_  
Time: \_\_\_\_\_

DepEd - SDO of Bulaca  
RECEIVED  
MAR 07 2022  
By: \_\_\_\_\_

3/8/2022

DR. ZENIA G. MOSTALES, EdD, CESO V  
SCHOOL DIVISION SUPERINTENDENT  
8006 (OFFICE) PROVINCIAL CAPITOL CMPD PROVINCIAL CAPITOL CPD MALOLOS CITY BULACAN

SUBJECT: INSPECTION REPORT OF POLLING PRECINCTS/CANVASSING CENTERS

Dear DR. ZENIA G. MOSTALES, EdD, CESO V,

In line with DOE's 2022 Election Taskforce, we would like to inform you that we have inspected the service entrance and wirings of your premises.

Inspection was done **February 2022**. Below are the findings and recommendations:

Please refer to attached **ANNEX A**.


We urge you to maintain the electrical safety and reliability of your premises before, during and after the elections to avoid any untoward incident.

CONTACT NO. 0998 968 9706

Our dedicated Relationship Manager **EDUARDO D. MENDOZA** will be ready to assist you for your needs.

We look forward to be of service.

Sincerely yours,

  
**ARNALDO C. PUNAY**  
Manager, Malolos Business Center

**ANNEX A - PAOMBONG**

POLLING/ CANVASSING	Complete Name of Establishment	Address	Date of Inspection	SIN	Meter No	REPAIR REMARKS
POLLING	LANTAD ELEM SCHOOL	ME(SCHOOL) 0775 LANTAD, SITIO LANTAD BINAKOD - PAOMBONG, PAOMBONG, BULACAN	2/10/2022	324072130101	721BAA011000	FOR REMODEL OF SE, PROVIDE SERVICE EQUIPMENT, FOR REHAB OF LOADSIDE WIRING
POLLING	MALUMOT.BARANGAY CHAPEL	@ 9003 MALUMOT, MALUMOT.MALUMOT - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	324090510101	23A5N04756	FOR REMODEL OF SE
POLLING	MASUKOL ELEM SCHOOL	RI(SCHOOL) 1950 WAWA I, SITIO WAWA I MASUKOL - PAOMBONG, PAOMBONG, BULACAN	2/10/2022	324093520103	33Y7N37940	INSTALL SERVICE EQUIPMENT, INSTALL ENCLOSURE @ FUSE/CB, INSTALL ADD'L OUTLETS PER RM, FOR REMODEL OF SE & WIRINGS.
POLLING	PINALAGDAN ELEMENTARY SCHOOL	@ 9005 PINALAGDAN, PINALAGDAN PINALAGDAN - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	324097260102	7198AC049660	NO / IMPROPER ENCLOSURE
POLLING	TAWIRAN ELEM SCH	@(SCHOOL) 9006 TAWIRAN, SITIO TAWIRAN SAN ISIDRO 1 - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	324121510101	709BA015462	WITH OCTOPUS CONNECTION,
POLLING	PAOMBONG RURAL HEALTH CENTER	9005@(MUNIP'L) POBLACION PAOMBONG BULACAN	2/3/2022	324150000101	711BAR08995	INSTALL METAL CLAMPS
POLLING	SAN JOSE ELEMENTARY SCHOOL	@(SCHOOL) 9008 PUROK 4, PUROK 4 SAN JOSE - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	324165820101	721BAA011256	INAPPROPRIATE SIZE OF WIRE
POLLING	SAN VICENTE BARANGAY CHAPEL	FR 0040 PUROK 2, PUROK 2 SAN VICENTE - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	324187590101	721BAA011255	REMODEL MTR/ NEW MTR# 721BAA011255
POLLING	SAN VICENTE DAY CARE CENTER	2115 PUROK 3 SAN VICENTE PAOMBONG BULACAN	2/3/2022	324190300101	721BAA011252	INAPPROPRIATE WIRE SIZE, W/ OCTOPUS CONNECTION

**ANNEX A - PAOMBONG**

POLLING/ CANVASSING	Complete Name of Establishment	Address	Date of Inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	STA CRUZ ELEMENTARY SCHOOL	@(SCHOOL) 9148 PUROK 5, PUROK 5 STA. CRUZ - PAOMBONG, PAOMBONG, BULACAN	2/10/2022	324197220102	720BAA007205	FOR REMODEL OF SE, PROVIDE SERVICE EQUIPMENT, NO SEPARATE FUSE/ CB PER ROOMS, NEED REWIRING, SOME LIGHTS ARE BUSTED, INSTALL ADD'L OUTLETS IN CLASSROOMS
POLLING	PAOMBONG ELEMENTARY SCHOOL,	@(SCHOOL) 9011 ELEM SAN ROQUE, SAN ROQUE SAN ROQUE - PAOMBONG, PAOMBONG, BULACAN	2/3/2022	457424440101	714FAL023707	INAPPROPRIATE SIZE OF WIRE

**ANNEX A - HAGONNOY**

POLLING / CANVASSING	Complete Name of Establishment	Address	Date of Inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	CARILLO ELEM SCHOOL	0085 PUROK 5 CARILLO HAGONNOY	2/14/2022	321399530101	721BAA011253	FOR REMODEL OF SE
POLLING	PUGAD ELEM.SCHOOL	ME(BESIDE) 2045 PUROK 1, PUROK 1 PUGAD - HAGONNOY, HAGONNOY, BULACAN	2/17/2022	321448600101	720BAA018132	FOR REMODEL OF SE
POLLING	SAGRADA FAMILIA ELEMENTARY SCHOOL	@ 9006 PUROK 5, PUROK 5 SAGRADA FAMILIA - HAGONNOY, HAGONNOY, BULACAN	2/3/2022	321467080101	717BAG023789	EMBEDDED GROUNDING ROD
POLLING	SAN NICOLAS ELEMENTARY SCHOOL	@(SCHOOL) 9006 PUROK 6, PUROK 6 SAN NICOLAS - HAGONNOY, HAGONNOY, BULACAN	2/9/2022	321592150104	719BAC040610	SUBSTANDARD LOADSIDE ENCLOSURE, FOR REMODEL OF SE
POLLING	SAN PABLO ELEMENTARY SCHOOL	LE 0103 PUROK 2, PUROK 2 SAN PABLO - HAGONNOY, HAGONNOY, BULACAN	2/3/2022	321594590103	718BAS079057	NEED PROPER WIRE SIZE OF LOADSIDE SUPPLYING EVERY BLDG
POLLING	SAN PASCUAL ELEM. SCHOOL	@(SCHOOL) 9001 PUROK 2, PUROK 2 SAN PASCUAL - HAGONNOY, HAGONNOY, BULACAN	2/14/2022	321610320103	112BAG040911	FOR REPLACEMENT OF SD, FOR REMODEL OF SE, FOR REPLACEMENT OF MAIN LOADSIDE WIRE, SOME LIGHTS WERE BUSTED
POLLING	SAN SEBASTIAN ELEMENTARY SCH	9004 @(SCHOOL) YAKAL MARY THE QUEEN HOMES SAN SEBASTIAN HAGONNOY BULACAN 3002	2/7/2022	321644470103	711BAR36126	FOR REL/REM OF SE
POLLING	VICTORIANO C. RAYMUNDO ELEMENTARY SCHOOL	@(BESIDE) 9002 PUROK 2, PUROK 2 STA. CRUZ - HAGONNOY, HAGONNOY, BULACAN	2/9/2022	321680200102	717EAC014729	SOME CLASSROOMS NEEDS ADD'L NEW OUTLET, NEED TO APPLY SEPARATE MERALCO MTR (SCHOOL IS USING MTR OF BGY HALL)

**ANNEX A - HAGONOY**

POLLING / CANVASSING	Comelec Name of Establishment	Address	Date of Inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	STA MONICA ELEM SCHOOL	FR(SCHOOL) 0081 PUROK 6, PUROK 6 STA. MONICA - HAGONOY, HAGONOY, BULACAN	2/14/2022	321714610101	720BAA005443	UPGRADE CB RATING, REPLACE BUSTED LIGHTING @ ROOMS
POLLING	TIBAGUIN ELEMENTARY SCHOOL	7440 RI PUROK 2 PUROK 2 TIBAGUIN HAGONOY BULACAN 3002	2/17/2022	321772480101	715BAG035720	FOR REMODEL OF SE, REPLACE BUSTED LIGHTING FIXTURES, INSTALL POWER SUPPLY ON OTHER RM
POLLING	SAN PEDRO ELEMENTARY SCHOOL	019 FR PUROK 1 SAN PEDRO HAGONOY BULACAN	2/3/2022	451186830101	713FAL004541	FD W/ SOME OPEN WIRINGSNO SEPARATE LOADSIDE WIRE FROM SE

**ANNEX A - CALUMPIT**

POLLING/ CANVASSING	Comlec Name of Establishment	Address	Date of inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	BALITE ELEMENTARY SCHOOL	@(SCHOOL) 9003 BALITE, BALITE BALITE - CALUMPIT, CALUMPIT, BULACAN	2/3/2022	321008270104	7088A005099	FD NO ENTRANCE CAP @ LINESIDE, ADVISED TO REMODEL SE, NEED TO REPL SERV EQUIPMENT, FD W/ EXPOSED LOADSIDE INSTALLATION & NEED TO FIX LOADSIDE
POLLING	CALIZON ELEM SCHOOL	@ 9006 SITIO 2, SITIO 2 CALIZON - CALUMPIT, CALUMPIT, BULACAN	2/15/2022	321047350101	711BAR24188	FOR REMODEL OF SE, AVOID USING EXTENSION CORDS
POLLING	CANIOGAN ELEM SCHOOL	FR(SCHOOL) 0062 DEL PILAR, PUROK 1 CANIOGAN - CALUMPIT, CALUMPIT, BULACAN	2/14/2022	321065310101	718BAS064539	FOR REMODEL OF SE, AVOID USING EXTENSION CORDS FOR OUTLET
POLLING	CALUMPIT CENTRAL SCHOOL	FR(SCHOOL) 0113 M. SERRANO, CORAZON CORAZON - CALUMPIT, CALUMPIT, BULACAN	2/14/2022	321081930101	711BAR22990	DETACHED RMC, FOR REMODEL OF SE, NEED TO REPL LOADSIDE INSTALLATION
POLLING	FRANCES ELEM SCHOOL	@(SCHOOL) 9002 PUROK 2, PUROK 2 FRANCES - CALUMPIT, CALUMPIT, BULACAN	2/15/2022	321094480101	715BAG030068	FOR REMODEL OF SE & UPGRADE / REPLACE LOADSIDE INSTALLATION
POLLING	GUGO PRIMARY SCHOOL	FR(SCHOOL) 6955 PUROK 2, PUROK 2 GUGO - CALUMPIT, CALUMPIT, BULACAN	2/15/2022	321131550101	711BAR17637	CUSTOMER REQUEST FOR FOR REMODEL OF SE & UPGRADE / REPLACE LOADSIDE INSTALLATION
POLLING	MEYULAO ELEMENTARY SCHOOL	@ 9001 PUROK 2, PUROK 2 MEYULAO - CALUMPIT, CALUMPIT, BULACAN	2/8/2022	321193870101	23ASN10713	REPLACE EXTENSION CORDS W/ THW WIRE LOADSIDE
POLLING	PANDUCOT ELEM SCHOOL	@ 9012 PUROK 4, PUROK 4 PANDUCOT - CALUMPIT, CALUMPIT, BULACAN	2/9/2022	321223950102	707BA016587	NEED TO REMODEL SE, NO SERVICE EQUIPMENT AFTER MTRG PT.
POLLING	F.MENDOZA MEM.ELEM.SCH OOL	@(SCHOOL) 9002 D. FAJARDO, POBLACION POBLACION - CALUMPIT, CALUMPIT, BULACAN	2/15/2022	321251010101	709BA065014	UPGRADE / REPLACE LOADSIDE INSTALLATION

**ANNEX A - CALUMPIT**

POLLING / CANVASSING	Complet Name of Establishment	Address	Date of Inspection	SIN	Meter No	REPAIR REMARKS
POLLING	PUNGO ELEM SCHOOL	@[SCHOOL] 9002 PUROK 2, PUROK 2 PUNGO - CALUMPIT, CALUMPIT, BULACAN	2/14/2022	321274270101	718BAS061307	FOR REMODEL OF SE , FD W/ EXPOSED / DILLAPIDATED LOADSIDE INSTALLATION, AVOID USING EXTENSION CORDS
POLLING	SAN MARCOS ELEMENTARY SCHOOL	ME[SCHOOL] 4850 PUROK 3, PUROK 3 SAN MARCOS - CALUMPIT, CALUMPIT, BULACAN	2/3/2022	321304460101	710BA039542 719BAC035236	NEED TO REMODEL SE, NEED TO FIX LOADSIDE INSTALLATION



**ANNEX A - PLARIDEL**

POLLING/ CANVASSING	Comelec Name of Establishment	Address	Date of inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	BANGA 2ND ELEMENTARY SCHOOL	(SCHOOL) 0245 VERGEL DE DIOS, BANGA 2 BANGA 2 - PLARIDEL, PLARIDEL, BULACAN	2/16/2022	324314860102	713BAR015163	FOR REMODEL OF SE, FOR INSTALLATION OF ADD'L C.O & LIGHTING OUTLETS, FOR REPAIR OF DEFECTIVE L.O. & C.O.
POLLING	BINTOG ELEMENTARY SCHOOL	FR 0433 J. MARIANO, PUROK 6 BINTOG - PLARIDEL, PLARIDEL, BULACAN	2/14/2022	324330330101	719BAC045146	FOR REMODEL OF SE, FOR ADD'L LIGHTING FIXTURES
POLLING	CULIANIN ELEMENTARY SCHOOL	@(SCHOOL) 9004 PUROK 3, PUROK 3 CULIANIN - PLARIDEL, PLARIDEL, BULACAN	2/14/2022	324354540101	707BA022198	FOR REMODEL OF SE, FOR REPLACEMENT OF BUSTED LIGHTING FIXTURES
POLLING	DAMPOL ELEMENTARY SCHOOL	FR 0116 PUROK 2, PUROK 2 DAMPOL - PLARIDEL, PLARIDEL, BULACAN	2/11/2022	324364150101	721BAA008312	FOR REMODEL OF SE, FOR REWIRING
POLLING	ROCKA MULTI PURPOSE HALL(TABANG)	@ 9001 SHALE, ROCKA VILL. II PH 3 PLARIDEL (Isolated) - PLARIDEL, PLARIDEL, BULACAN	2/8/2022	324441440103	23AB807049	FOR REMODEL OF SE, INSTALL NEMA 3R CB AFTER M/S
POLLING	PLARIDEL CENTRAL SCHOOL	FR(COMP) 0472 JAVIER ST, POBLACION POBLACION - PLARIDEL, PLARIDEL, BULACAN	2/15/2022	324470350101	708BA014590/ 709BA015053	FOR REMODEL OF SE, FOR REPLACEMENT OF DILLAPIDATED C.O & LIGHTING FIXTURES. INSTALL ADD'L LIGHTING FIXTURES

**ANNEX A - PLARIDEL**

POLLING/ CANVASSING	Comelec Name of Establishment	Address	Date of inspection	SIN	Meter No.	REPAIR REMARKS
POLLING	SAN JOSE ELEM SCHOOL	@ 9001 ILANG-ILANG, PUROK ILANG-ILANG SAN JOSE - PLARIDEL, PLARIDEL, BULACAN	2/14/2022	324490730101	716BAG019894	FOR REMODEL OF SE, FOR INSTALLATION & REPLACEMENT OF BUSTED LIGHTING FIXTURES
POLLING	STA INES DAYCARE/ BASKETBALL COURT	0049 SAN ROQUE, STA. INES STA. INES - PLARIDEL, PLARIDEL, BULACAN	2/11/2022	324515410101	709BA065084	FOR REMODEL OF SE, FD USING EXTENSION CORD OTHER OUTLETS DILLAPIDATED
POLLING	STO NIÑO ELEMENTARY SCHOOL	(SCHOOL) 0346 GOV. PADILLA, PUROK 3 STO. NIÑO - PLARIDEL, PLARIDEL, BULACAN	2/15/2022	324535120101	708BA028643	FOR REMODEL OF SE, FOR REPLACEMENT OF DILLAPIDATED C.O & LIGHTING FIXTURES. INSTALL ADD'L LIGHTING FIXTURES

DepEd - SDO of Bulacan  
**RECEIVED**  
 MAR 07 2022  
 By: *[Signature]*